

SECTION 28 46 00

FIRE DETECTION AND ALARM

PART 1.0 - GENERAL

1.1. DESCRIPTION:

A. This section of the specification includes the furnishing, installation, and connection and certification of a microprocessor controlled, analog addressable, intelligent fire alarm equipment required to form a complete coordinated system ready for operation. It shall include, but not be limited to, alarm initiating devices, alarm notification appliances, control panels, auxiliary control devices, annunciators, power supplies, and wiring as shown on the drawings and specified herein.

B. The fire alarm system shall comply with requirements of NFPA Standard 72 for Protected Premises Signaling Systems except as modified and supplemented by this specification. The system shall be electrically supervised and monitor the integrity of all conductors.

C. The system shall be an active/interrogative type system where each addressable device is repetitively scanned, causing a signal to be transmitted to the main fire alarm control panel (FACP) indicating that the device and its associated circuit wiring is functional. Loss of this signal at the main FACP shall result in a trouble indication as specified hereinafter for the particular input.

D. The fire alarm system shall be manufactured by an ISO 9001 certified company and meet the requirements of BS EN9001: ANSI/ASQC Q9001-1994.

E. The system and its components shall be Underwriters Laboratories, Inc. listed under the appropriate UL testing standard as listed herein for fire alarm applications and the installation shall be in compliance with the UL listing.

1.2. SCOPE:

A. A new intelligent reporting, microprocessor-controlled fire detection system shall be installed in accordance with the specifications and drawings.

B. The system shall be designed such that each signaling line circuit (SLC) is limited to only 80% of its total capacity at initial installation.

C. Basic Performance:

1. Alarm, trouble and supervisory signals from all intelligent reporting devices shall be encoded on NFPA Style 4 (Class B) Signaling Line Circuits (SLC).

2. Initiation Device Circuits (IDC) shall be wired Class B (NFPA Style Z) as part of an addressable device connected by the SLC Circuit.

3. Notification Appliance Circuits (NAC) shall be wired Class B (NFPA Style Y) as part of an addressable device connected by the SLC Circuit.

4. On Style 4 (Class B) configurations a single ground fault or open circuit on the system Signaling Line Circuit (SLC) shall not cause system malfunction, loss of operating power or the ability to report an alarm.

5. Alarm signals arriving at the FACP shall not be lost following a primary power failure (or outage) until the alarm signal is processed and recorded.

D. BASIC SYSTEM FUNCTIONAL OPERATION

When a fire alarm condition is detected and reported by one of the system initiating devices, the following functions shall immediately occur:

1. The system alarm LED on the system display shall flash.

2. A local piezo electric signal in the control panel shall sound.

3. A backlit LCD display shall indicate all information associated with the fire alarm

condition, including the type of alarm point and its location within the protected premises.

4. History storage equipment shall log the information associated with each new fire alarm control panel condition, along with time and date of occurrence.

5. All system output programs assigned via control-by-event interlock programming to be activated by the particular point in alarm shall be executed, and the associated system outputs (notification appliances and/or relays) shall be activated.

1.3. SUBMITTALS

A. General:

1. Submission of submittals for review and comment. In addition to distribution requirements for Submittals specified in Division 1 Section "Submittals", make an identical submission to UNC facilities for review and comment. After incorporating any Engineer/UNC Facilities comments submit to The Greeley Fire Department (AHJ). Include copies of annotated Contract Drawings as needed to depict component locations to facilitate review. Resubmit if required to make clarifications or revisions to obtain approval. Fire alarm shop drawings shall be sealed and signed by a professional engineer (P.E.) licensed in Colorado, who shall certify that the fire alarm installation meets requirements of the local codes and applicable sections of NFPA. Additionally, a NICET level 3 or 4 Technician shall stamp fire alarm shop drawings. Upon receipt of comments from authorities having jurisdiction, submit them to the Project Architect/Engineer for review. Include all AHJ comments with the submittal.

2. All references to manufacturer's model numbers and other pertinent information herein is intended to establish minimum standards of performance, function and quality. Equivalent compatible UL-listed equipment from other manufacturers may be substituted for the specified equipment as long as the minimum standards are met.

3. For equipment other than that specified, the contractor shall supply proof that such substitute equipment equals or exceeds the features, functions, performance, and quality of the specified equipment.

B. Shop Drawings:

1. Sufficient information, clearly presented, shall be included to determine compliance with drawings and specifications.
2. Include manufacturer's name(s), model numbers, ratings, power requirements, equipment layout, device arrangement, complete wiring point-to-point diagrams, and conduit layouts.
3. Show annunciator layout, configurations, and terminations.
4. Battery back-up calculations will be submitted for approval.

C. Manuals:

1. Submit simultaneously with the shop drawings, complete operating and maintenance manuals listing the manufacturer's name(s), including technical data sheets.
2. Wiring diagrams shall indicate internal wiring for each device and the interconnections between the items of equipment.
3. Provide a clear and concise description of operation that gives, in detail, the information required to properly operate the equipment and system.

D. Software Modifications

1. Provide the services of a factory trained and authorized technician to perform all system software modifications, upgrades or changes. Response time of the technician to the site shall not exceed 2 hours.
2. Provide all hardware, software, programming tools, source codes and documentation necessary to modify the fire alarm system on site. Modification includes addition and deletion of devices, circuits, zones and changes to system operation and custom label changes for devices or zones. The system structure and software shall place no limit on the type or extent of software modifications on-site.

E. Certifications:

1. Together with the shop drawing submittal, submit a certification from the major equipment manufacturer indicating that the proposed supervisor of the installation and the proposed performer of contract maintenance is an authorized representative of the major equipment manufacturer. Include names and addresses in the certification.

2. Certificate of Completion: Comply with NFPA 72.

1.4. GUARANTY:

A. All work performed and all material and equipment furnished under this contract shall be free from defects and shall remain so for a period of at least one (1) year from the date of acceptance. The full cost of maintenance, labor and materials required to correct any defect during this one year period shall be included in the submittal bid.

B. Provide the Owner with a three year guaranteed price list of parts used on the project for replacement.

1.5. APPLICABLE STANDARDS AND SPECIFICATIONS:

The specifications and standards listed below form a part of this specification. The system shall fully comply with the latest issue of these standards, if applicable.

A. National Fire Protection Association (NFPA) - USA:

No. 12 CO2 Extinguishing Systems (low and high)

No. 12B Halon 1211 Extinguishing Systems

No. 13 Sprinkler Systems

No. 13A Halon 1301 Extinguishing Systems

No. 15 Water Spray Systems

No. 16 Foam/Water Deluge and Spray Systems

No. 17 Dry Chemical Extinguishing Systems

No. 17A Wet Chemical Extinguishing Systems

Clean Agent Extinguishing Systems

No. 72 National Fire Alarm Code

No. 101 Life Safety Code

B. Underwriters Laboratories Inc. (UL) - USA:

No. 268 Smoke Detectors for Fire Protective Signaling Systems

No. 864 Control Units for Fire Protective Signaling Systems

No. 268A Smoke Detectors for Duct Applications

No. 521 Heat Detectors for Fire Protective Signaling Systems

No. 464 Audible Signaling Appliances

No. 38 Manually Actuated Signaling Boxes

No. 346 Water flow Indicators for Fire Protective Signaling Systems

No. 1076 Control Units for Burglar Alarm Proprietary Protective Signaling Systems

No. 1971 Visual Notification Appliances

UUKL

C. Local and State Building Codes.

D. All requirements of the Authority Having Jurisdiction (AHJ).

1.6. APPROVALS:

A. The system shall have proper listing and/or approval from the following nationally recognized agencies:

UL Underwriters Laboratories Inc

ULC Underwriters Laboratories Canada

FM Factory Mutual

MEA Material Equipment Acceptance (NYC)

CSFM California State Fire Marshal

B. The fire alarm control panel shall meet UL Standard 864 (Control Units) and UL Standard 1076 (Proprietary Burglar Alarm Systems).

- C. The system shall be listed by the national agencies as suitable for extinguishing release applications. The system shall support release of high and low pressure CO₂.
- D. Modular Labeling: The fire alarm control panel shall meet the modular listing requirements of Underwriters Laboratories Inc. To facilitate system changes and expansions, and to ensure that all subassemblies have the proper listing, each subassembly of the FACP shall carry the appropriate UL modular label. This includes all printed circuit board assemblies, power supplies, and enclosure parts.

1.7 QUALITY ASSURANCE

- A. Installer Qualifications: An experienced installer with a minimum of 5 years fire alarm installation experience and NICET Level 2 Technician or greater supervising the installation. The installing technician shall provide written proof of NICET level 2 certification to UNC.
- B. Authorized distributor: The manufacturer's authorized distributor shall confirm that they have an established agency which stocks a full complement of parts and offers service during normal working hours on all equipment to be furnished and that the agency will supply parts and service without delay and at a reasonable cost. Maximum response time for service calls is two hours or less.
- C. The work described in this specification consists of all labor, materials, equipment, and services necessary and required to complete and test the automatic fire detection and alarm system. Any material not specifically mentioned in this specification or not shown on drawings, but required for proper performance and operation as specified, shall be furnished and installed and considered part of the system at no extra charge to the Owner.

1.8 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed for all systems and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Strobe Units, Horn units and horn/strobe combination units, speaker and speaker/strobe combination units: Quantity equal to 5 percent of amount installed, but not less than one

unit of each type.

2. Smoke Detectors, Heat/Fire Detectors, and Flame Detectors: Quantity equal to 5 percent of amount of each type installed, but not less than one unit of each type.

3. Detector Bases: Quantity equal to 2 percent of amount of each type installed, but not less than one unit of each type.

4. Manual pull stations, monitor modules and control modules: Quantity equal to 5 percent of amount of each type installed, but not less than one unit of each type.

5. Keys and Tools: One extra set for access to locked and tamper proof components.

PART 2.0 - PRODUCTS

2.1 MANUFACTURERS

A. Subject to compliance with the specified requirements, provide products by either “Notifier by Honeywell” or Honeywell. Depending upon project size requirements and UNC IT network infrastructure and capabilities, either wire or fiber optic connected, provide either a Notifier Onyxworks NFS2-3030, NFS2-640, NFS 320 system, Notifier Inspire series N16e or N16x or a Honeywell XLS140-2, XLS-3000 or XLS-4000 system to be networked into the existing campus Notifier Onyxworks v4.62.102 or Honeywell EBi v610 network.

2.2. EQUIPMENT AND MATERIAL, GENERAL:

A. All equipment and components shall be new, and the manufacturer's current model. The materials, appliances, equipment and devices shall be tested and listed by a nationally recognized approvals agency for use as part of a protected premises protective signaling (fire alarm) system. The authorized representative of the manufacturer of the major equipment, such as control panels, shall be responsible for the satisfactory installation of the complete system.

B. All equipment and components shall be installed in strict compliance with manufacturers' recommendations. Consult the manufacturer's installation manuals for all wiring diagrams,

schematics, physical equipment sizes, etc., before beginning system installation. Refer to the Riser/Connection diagram for all specific system installation/termination/wiring data.

- C. All equipment shall be attached to walls and ceiling/floor assemblies and shall be held firmly in place (e.g., detectors shall not be supported solely by suspended ceilings). Fasteners and supports shall be adequate to support the required load.

2.3. CONDUIT AND WIRE:

A. Conduit:

1. Conduit shall be in accordance with The National Electrical Code (NEC), local and state requirements.
2. Where possible, all wiring shall be installed in conduit or raceway. Conduit fill shall not exceed 40 percent of interior cross-sectional area where three or more cables are contained within a single conduit.
3. Cable must be separated from any open conductors of Power, or Class 1 circuits, and shall not be placed in any conduit, junction box or raceway containing these conductors, as per NEC Article 760-29.
4. Wiring for 24-volt control, alarm notification, emergency communication and similar power-limited auxiliary functions shall not be run in the same conduit as initiating and signaling line circuits. All circuits shall be provided with transient suppression devices and the system shall be designed to permit simultaneous operation of all circuits without interference or loss of signals.
5. Conduit shall not enter the fire alarm control panel, or any other remotely mounted control panel equipment or back boxes, except where conduit entry is specified by the FACP manufacturer.
6. Conduit shall be 3/4 inch (19.1 mm) minimum.

B. Wire:

1. All fire alarm system wiring must be new.
2. Wiring shall be in accordance with local, state and national codes (e.g., NEC Article 760) and as recommended by the manufacturer of the fire alarm system. Number and size of conductors shall be as recommended by the fire alarm system manufacturer, but not less than 18 AWG (1.02 mm) for initiating device circuits and signaling line circuits, and 14 AWG (1.63 mm) for notification appliance circuits.
3. All wire and cable shall be listed and/or approved by a recognized testing agency for use with a protective signaling system.
4. Wire and cable not installed in conduit shall have a fire resistance rating suitable for the installation as indicated in NFPA 70 (e.g., FPLR).
5. Wiring used for the multiplex communication circuit (SLC) shall be twisted and unshielded and support a minimum wiring distance of 12,500 feet. The design of the system shall permit use of IDC and NAC wiring in the same conduit with the SLC communication circuit.
6. All field wiring shall be electrically supervised for open circuit and ground fault.
7. The Fire Alarm Control panel shall be capable of T-Tapping Class B (NFPA Style 4) Signaling Line Circuits. Systems which do not allow, have restrictions to, for example, the amount of T-Taps, length of T-Taps etc., are not acceptable.
8. Wiring connecting remote fire alarm panels shall be capable of supporting voice signals.

C. Terminal Boxes, Junction Boxes and Cabinets:

All boxes and cabinets shall be UL listed for their use and purpose.

D. Initiating circuits shall be arranged to serve like categories (manual, smoke, water flow). Mixed category circuitry shall not be permitted except on signaling line circuits connected to intelligent reporting devices.

E. The fire alarm control panel shall be connected to a separate dedicated branch circuit, maximum 20 amperes. This circuit shall be labeled at the main power distribution panel as FIRE ALARM. Fire alarm control panel primary power wiring shall be 12 AWG.

2.4. MAIN FIRE ALARM CONTROL PANEL OR NETWORK NODE:

A. The main FACP Central Console shall contain a microprocessor based Central Processing Unit (CPU). The CPU shall communicate with and control the following types of equipment used to make up the system: intelligent addressable smoke and thermal (heat) detectors, addressable modules, panel modules including initiating circuits, control circuits, and notification appliance circuits, local and remote operator terminals, printers, annunciators, and other system controlled devices.

1. In conjunction with intelligent Loop Control Modules and Loop Expander Modules, the main FACP shall perform the following functions:

a. Supervise and monitor all intelligent addressable detectors and monitor modules connected to the system for normal, trouble and alarm conditions.

b. Supervise all initiating signaling and notification appliance circuits throughout the facility by way of connection to monitor and control modules.

c. Detect the activation of any initiating device and the location of the alarm condition. Operate all notification appliances and auxiliary devices as programmed. In the event of CPU failure, all SLC loop modules shall fallback to degrade mode. Such degrade mode shall treat the corresponding SLC loop control modules and associated detection devices as conventional two-wire operation. Any activation of a detector in this mode shall automatically activate associated Notification Appliance Circuits.

d. Visually and audibly annunciate any trouble, supervisory, security or alarm condition on operator's terminals, panel display, and annunciators.

2. When a fire alarm condition is detected and reported by one of the system initiating devices or appliances, the following functions shall immediately occur:

- a. The system alarm LED shall flash.
- b. A local piezo-electric audible device in the control panel shall sound a distinctive signal.
- c. The 640-character backlit LCD or LED display shall indicate all information associated with the fire alarm condition, including the type of alarm point and its location within the protected premises.
- d. History storage equipment shall log the event information along with a time and date stamp.
- e. All system outputs assigned via pre-programmed equations for a particular point in alarm shall be executed, and the associated system outputs (alarm notification appliances and/or relays) shall be activated.

3. When a trouble condition is detected and reported by one of the system initiating devices or appliances, the following functions shall immediately occur:

- a. The system trouble LED shall flash.
- b. A local piezo-electric audible device in the control panel shall sound a distinctive signal.
- c. The 640-character backlit LCD or LED display shall indicate all information associated with the trouble condition, including the type of trouble point and its location within the protected premises.
- d. History storage equipment shall log the event information along with a time and date stamp.

4. When a supervisory condition is detected and reported by one of the system initiating devices or appliances, the following functions shall immediately occur:

- a. The system supervisory LED shall flash.

b. A local piezo-electric audible device in the control panel shall sound a distinctive signal.

c. The 640-character backlit LCD or LED display shall indicate all information associated with the supervisory condition, including the type of trouble point and its location within the protected premises.

d. History storage equipment shall log the event information along with a time and date stamp.

e. All system outputs assigned via pre-programmed equations for a particular point in supervisory alarm shall be executed, and the associated system outputs shall be activated.

5. When a pre-alarm condition is detected and reported by one of the system initiating devices or appliances, the following functions shall immediately occur:

a. The system pre-alarm LED shall flash.

b. A local piezo-electric audible device in the control panel shall sound a distinctive signal.

c. The 640-character backlit LCD or LED display shall indicate all information associated with the pre-alarm condition, including the type of alarm point and its location within the protected premises.

d. History storage equipment shall log the event information along with a time and date stamp.

e. All system outputs assigned via pre-programmed equations for a particular point in pre-alarm shall be executed, and the associated system outputs shall be activated.

B. Operator Control

1. Acknowledge Switch:

- a. Activation of the control panel acknowledge switch in response to new alarms and/or troubles shall silence the local panel piezo electric signal and change the alarm and trouble LEDs from flashing mode to steady-ON mode. If multiple alarm or trouble conditions exist, depression of this switch shall advance the LCD display to the next alarm or trouble condition. In addition, the FACP shall support Block Acknowledge to allow multiple trouble conditions to be acknowledged with a single depression of this switch.
- b. Depression of the Acknowledge switch shall also silence all remote annunciator piezo sounders.

C. Signal Silence Switch:

Depression of the Signal Silence switch shall cause all programmed audible alarm notification appliances to return to the normal condition. The selection of audible notification circuits that are silenceable by this switch shall be fully field programmable within the confines of all applicable standards. The FACP software shall include silence inhibit and auto-silence timers.

1. Drill Switch: Depression of the Drill switch shall activate all programmed notification appliance circuits. The drill function shall latch until the panel is silenced or reset.
2. System Reset Switch: Depression of the System Reset switch shall cause all electronically latched initiating devices to return to their normal condition. Initiating devices shall re-report if active. Active notification appliance circuits shall silence upon Reset. Systems that de-activate and subsequently re-activate notification appliance circuits shall not be considered equal. All programmed Control-By-Event equations shall be re-evaluated after the reset sequence is complete if the initiating condition has cleared. Non-latching trouble conditions shall not clear and re-report upon reset.
3. Lamp Test: The Lamp Test switch shall activate all local system LEDs, light each segment of the liquid crystal display, and display the panel software revision for service personal.

4. Scroll Display Keys: There shall be Scroll Display keys for FIRE ALARM, SECURITY, SUPERVISORY, TROUBLE, and OTHER EVENTS. Depression of the Scroll Display key shall display the next event in the selected queue allowing the operator to view events by type.

D. System Capacity and General Operation

1. The control panel shall be sized with at least 10% spare points per SLC circuit.
2. The Fire Alarm Control Panel shall include a full featured operator interface control and annunciation panel that shall include a backlit 640-character liquid crystal display, individual, color coded system status LEDs, and a QWERTY style alphanumeric keypad for the field programming and control of the fire alarm system. Said LCD shall also support graphic bit maps capable of displaying the company name and logo of either the owner or installing company.
3. All programming or editing of the existing program in the system shall be achieved without special equipment and without interrupting the alarm monitoring functions of the fire alarm control panel.
4. The FACP shall be able to provide the following software and hardware features:
 - a. Pre-signal and Positive Alarm Sequence: The system shall provide means to cause alarm signals to only sound in specific areas with a delay of the alarm from 60 to up to 180 seconds after start of alarm processing. In addition, a Positive Alarm Sequence selection shall be available that allows a 15-second time period for acknowledging an alarm signal from a fire detection/initiating device. If the alarm is not acknowledged within 15 seconds, all local and remote outputs shall automatically activate immediately.
 - b. Smoke Detector Pre-alarm Indication at Control Panel: To obtain early warning of incipient or potential fire conditions, the system shall support a programmable option to determine system response to real-time detector sensing values above the programmed setting. Two levels of Pre-alarm indication shall be available at the control panel: alert and action.

c. Alert: It shall be possible to set individual smoke detectors for pre-programmed pre-alarm thresholds. If the individual threshold is reached, the pre-alarm condition shall be activated.

d. Action: If programmed for action and the detector reaches a level exceeding the pre-programmed level, the control panel shall indicate an action condition. Sounder bases installed with either heat or smoke detectors shall automatically activate on action Pre-Alarm level, with general evacuation on alarm level.

e. The system shall support a detector response time to meet world annunciation requirements of less than 3 seconds.

f. Device Blink Control: Means shall be provided to turn off detector/module LED strobes for special areas.

g. NFPA 72 Smoke Detector Sensitivity Test: The system shall provide an automatic smoke detector test function that meets the requirements of NFPA 72.

h. Programmable Trouble Reminder: The system shall provide means to automatically initiate a reminder that troubles exist in the system. The reminder will appear on the system display and (if enabled) will sound a piezo alarm.

i. On-line or Off-line programming: The system shall provide means to allow panel programming either through an off-line software utility program away from the panel or while connected and on-line. The system shall also support upload and download of programmed database and panel executive system program to a Personal Computer/laptop.

j. History Events: The panel shall maintain a history file of the last 4000 events, each with a time and date stamp. History events shall include all alarms, troubles, operator actions, and programming entries. The control panels shall also maintain a 1000 event Alarm History buffer, which consists of the 1000 most recent alarm events from the 4000 event history file.

k. Smoke Control Modes: The system shall provide means to perform FSCS mode Smoke Control to meet NFPA-92A and 90B and HVAC mode to meet

NFPA 90A.

l. The system shall provide means for all SLC devices on any SLC loop to be auto programmed into the system by specific address. The system shall recognize specific device type ID's and associate that ID with the corresponding address of the device.

m. Drill: The system shall support means to activate all silenceable fire output circuits in the event of a practice evacuation or "drill". If enabled for local control, the front panel switch shall be held for a minimum of 2 seconds prior to activating the drill function

n. Passwords and Users: The system shall support two password levels, master and user. Up to 9 user passwords shall be available, each of which may be assigned access to the programming change menus, the alter status menus, or both. Only the master password shall allow access to password change screens.

o. Two Wire Detection: The system shall support standard two wire detection devices specifically all models of System Sensor devices-

p. Block Acknowledge: The system shall support a block Acknowledge for Trouble Conditions

q. Sensitivity Adjust: The system shall provide Automatic Detector Sensitivity Adjust based on Occupancy schedules including a Holiday list of up to 15 days.

r. Environmental Drift Control: The system shall provide means for setting Environmental Drift Compensation by device. When a detector accumulates dust in the chamber and reaches an unacceptable level but yet still below the allowed limit, the control panel shall indicate a maintenance alert warning. When the detector accumulates dust in the chamber above the allowed limit, the control panel shall indicate a maintenance urgent warning.

s. Custom Action Messages: The system shall provide means to enter up to 100 custom action messages of up to 160 characters each. It shall be possible to assign any of the 100 messages to any point.

t. Log Functions: The system shall provide means to log a variety of reports listing all event, alarm, trouble, supervisory, or security history. Additional reports shall be available for point activation for the last Walk Test performed, detector maintenance report containing the detector maintenance status of each installed addressable detector, all network parameters, all panel settings including broadcast time, event ordering, and block acknowledge, panel timer values for Auto Silence, Silence Inhibit, AC Fail Delay time and if enabled, Proprietary Reminder, and Remote Reminder timers, supervision settings for power supply and printers, all programmed logic equations, all custom action messages, all non-fire and output activations (if pre-programmed for logging) all active points filtered by alarms only, troubles only, supervisory alarms, pre-alarms, disabled points and activated points, all installed points filtered by SLC points, panel circuits, logic zones, annunciators, releasing zones, special zones, and trouble zones.

u. Local Mode: If communication is lost to the central processor the system shall provide added survivability through the intelligent loop control modules. Inputs from devices connected to the SLC and loop control modules shall activate outputs on the same loop when the inputs and outputs have been set with point programming to participate in local mode or when the type codes are of the same type: that is, an input with a fire alarm type code shall activate an output with a fire alarm type code.

v. Resound based on type for security or supervisory: The system shall indicate a Security alarm when a monitor module point programmed with a security Type Code activates. If silenced alarms exist, a Security alarm will resound the panel sounder. The system shall indicate a Supervisory alarm when a monitor module point programmed with a supervisory Type Code activates. If there are silenced alarms, a Supervisory alarm will resound the panel sounder.

w. Read status preview - enabled and disabled points: Prior to re-enabling points, the system shall inform the user that a disabled device is in the alarm state. This shall provide notice that the device must be reset before the device is enabled thereby avoiding activation of the notification circuits.

x. Custom Graphics: When fitted with an LCD or LED display, the panel shall permit uploading of a custom bit-mapped graphic to the display screen. Graphic shall display when all systems are normal.

y. Multi-Detector and Cooperating Detectors: The system shall provide means to link one detector to up to two detectors at other addresses on the same loop in cooperative multi-detector sensing. There shall be no requirement for sequential addresses on the detectors and the alarm event shall be a result or product of all cooperating detectors chamber readings.

z. Tracking/Latching Duct (~~ion and photo~~): The system shall support ~~both~~ tracking and latching duct detectors ~~either ion or photo types~~.

aa. ACTIVE EVENT: The system shall provide a Type ID called FIRE CONTROL for purposes of air-handling shutdown, which shall be intended to override normal operating automatic functions. Activation of a FIRE CONTROL point shall cause the control panel to (1) initiate the monitor module Control-by-Event, (2) send a message to the panel LCD or LED display, history buffer, installed printer and annunciators, (3) shall not light an indicator at the control panel, (4) Shall display ACTIVE on the LCD as well a display a FIRE CONTROL Type Code and other information specific to the device.

bb. NON-FIRE Alarm Module Reporting: A point with a type ID of NON-FIRE shall be available for use for energy management or other non-fire situations. NON-FIRE point operation shall not affect control panel operation nor shall it display a message at the panel LDC. Activation of a NON-FIRE point shall activate control by event logic but shall not cause any indication on the control panel.

cc. Security Monitor Points: The system shall provide means to monitor any point as a type security.

dd. One-Man Walk Test: The system shall provide both a basic and advanced walk test for testing the entire fire alarm system. The basic walk test shall allow a single operator to run audible tests on the panel. All logic equation automation shall be suspended during the test and while annunciators can be enabled for the

test, all shall default to the disabled state. During an advanced walk test, field-supplied output point programming will react to input stimuli such as CBE and logic equations. When points are activated in advanced test mode, each initiating event shall latch the input. The advanced test shall be audible and shall be used for manual pull station verification, magnet activated tests on input devices, input and output device and wiring operation/verification.

ee. Control By Event Functions: CBE software functions shall provide means to program a variety of output responses based on various initiating events. The control panel shall operate CBE through lists of zones. A zone shall become listed when it is added to a point's zone map through point programming. Each input point such as detector, monitor module or panel circuit module shall support listing of up to 10 zones into its programmed zone map.

ff. Permitted zone types shall be general zone, releasing zone and special zone. Each output point (control module, panel circuit module) can support a list of up to 10 zones including general zone, logic zone, releasing zone and trouble zone. It shall be possible for output points to be assigned to list general alarm. Non-Alarm or Supervisory points shall not activate the general alarm zone.

gg. 1000 General Zones: The system shall support up to 1000 general purpose software zones for linking inputs to outputs. When an input device activates, any general zone programmed into that device's zone map will be active and any output device that has an active general zone in its map will be active. It shall also be possible to use general zone as arguments in logic equations.

hh. 1000 Logic Equations: The system shall support up to 1000 logic equations for AND, OR, NOT, ONLY1, ANYX, XZONE or RANGE operators that allow conditional I/O linking. When any logic equation becomes true, all output points mapped to the logic zone shall activate.

ii. Ten trouble equations per device: The system shall provide support for up to 10 trouble equations for each device, which shall permit programming parameters to be altered, based on specific fault conditions. If the trouble equation becomes true, all output points mapped to the trouble zone shall activate.

jj. Control-By-Time: A time based logic function shall be available to delay an action for a specific period of time based upon a logic input with tracking feature. A latched version shall also be available. Another version of this shall permit activation on specific days of the week or year with ability to set and restore based on a 24 hour time schedule on any day of the week or year.

kk. Multiple agent releasing zones: The system shall support up to 10 releasing zones to protect against 10 independent hazards. Releasing zones shall provide up to three cross-zones with four abort options to satisfy any local jurisdiction requirements.

ll. Alarm Verification, by device, with timer and tally: The system shall provide a user-defined global software timer function that can be set for a specific detector or indicating panel module input. The timer function shall delay an alarm signal for a user-specified time period and the control panel shall ignore the alarm verification timer if another alarm is detected during the verification period. It shall also be possible to set a maximum verification count between 0 and 20 with the "0" setting producing no alarm verification. When the counter exceeds the threshold value entered, a trouble shall be generated to the panel.

E. Central Processing Unit

1. The Central Processing Unit shall communicate with, monitor, and control all other modules within the control panel. Removal, disconnection or failure of any control panel module shall be detected and reported to the system display by the Central Processing Unit.
2. The Central Processing Unit shall contain and execute all control-by-event (including Boolean functions including but not limited to AND, OR, NOT, ANY_x, and CROSSZONE) programs for specific action to be taken if an alarm condition is detected by the system. Such control-by-event programs shall be held in non-volatile programmable memory, and shall not be lost with system primary and secondary power failure.
3. The Central Processing Unit shall also provide a real-time clock for time annotation,

to the second, of all system events. The time-of-day and date shall not be lost if system primary and secondary power supplies fail.

4. The CPU shall be capable of being programmed on site without requiring the use of any external programming equipment. Systems that require the use of external programmers or change of EPROMs are not acceptable.

5. Consistent with UL864 standards, the CPU and associated equipment are to be protected so that voltage surges or line transients will not affect them.

6. Each peripheral device connected to the CPU shall be continuously scanned for proper operation. Data transmissions between the CPU and peripheral devices shall be reliable and error free. The transmission scheme used shall employ dual transmission or other equivalent error checking techniques.

7. The CPU shall provide an EIA-232 interface between the fire alarm control panel and the UL Listed Electronic Data Processing (EDP) peripherals.

8. The CPU shall provide two EIA-485 ports for the serial connection to annunciation and control subsystem components.

9. The EIA-232 serial output circuit shall be optically isolated to assure protection from earth ground.

10. The CPU shall provide one high-speed serial connection for support of network communication modules.

11. The CPU shall provide double pole relays for FIRE ALARM, SYSTEM TROUBLE, SUPERVISORY, and SECURITY. The SUPERVISORY and SECURITY relays shall provide selection for additional FIRE ALARM contacts.

12. BACnet interface devices will be provided as needed for other control systems to interface with the fire alarm system.

13. A Honeywell system shall have a Fire Network Adapter card, either wired or fiber optic, for direct connection of signal transmission to the UNC Honeywell EBi v610

server located in the IT Equipment Room Q1206 in Gray Hall. A Notifier system shall be provided with either an NFN-GW-EM-3 wired network interface card, or fiber optic equivalent in the case of a N16e or N16x, for direct connection of signal transmission to the two Onyxworks workstations, v4.62.102, located in Parsons Hall Building Automation office 1147 and the campus Police Dispatch office located on 1st floor of Gray Hall.

F. Display

1. The system display shall provide all the controls and indicators used by the system operator and may also be used to program all system operational parameters.
2. The display assembly shall contain, and display as required, custom alphanumeric labels for all intelligent detectors, addressable modules, and software zones.
3. The system display shall provide a 640-character backlit alphanumeric Liquid Crystal Display (LCD) or LED display. It shall also provide ten Light-Emitting-Diodes (LEDs) that indicate the status of the following system parameters: AC POWER, FIRE ALARM, PREALARM, SECURITY, SUPERVISORY, SYSTEM TROUBLE, OTHER EVENT, SIGNALS SILENCED, POINT DISABLED, and CPU FAILURE.
4. The system display shall provide a QWERTY style keypad with control capability to command all system functions, entry of any alphabetic or numeric information, and field programming. Two different password levels with up to ten (one Master and nine User) passwords shall be accessible through the display interface assembly to prevent unauthorized system control or programming.
5. The system display shall include the following operator control switches: ACKNOWLEDGE, SIGNAL SILENCE, RESET, DRILL, and LAMP TEST. Additionally, the display interface shall allow scrolling of events by event type including, FIRE ALARM, SECURITY, SUPERVISORY, TROUBLE, and OTHER EVENTS. A PRINT SCREEN button shall be provided for printing the event currently displayed on the 640-character LCD.

G. Loop (Signaling Line Circuit) Control Module:

1. The Loop Control Module shall monitor and control a minimum of 318 intelligent addressable devices. This includes 159 intelligent detectors (Ionization, Photoelectric, or Thermal or combination) and 159 monitor or control modules.
2. The Loop Control Module shall contain its own microprocessor and shall be capable of operating in a local/degrade mode (any addressable device input shall be capable of activating any or all addressable device outputs) in the unlikely event of a failure in the main CPU.
3. The Loop Control Module shall provide power and communicate with all intelligent addressable detectors and modules on a single pair of wires. This SLC Loop shall be capable of operating as a NFPA Style 4 (Class B) circuit.
4. The SLC interface board shall be able to drive an NFPA Style 4 twisted shielded circuit up to 12,500 feet in length. The SLC Interface shall also be capable of driving an NFPA Style 4, no twist, no shield circuit up to 3,000 feet in length. In addition, SLC wiring shall meet the listing requirements for it to exit the building or structure. "T"-tapping shall be allowed in either case.
5. The SLC interface board shall receive analog or digital information from all intelligent detectors and shall process this information to determine whether normal, alarm, or trouble conditions exist for that particular device. Each SLC Loop shall be isolated and equipped to annunciate an Earth Fault condition. The SLC interface board software shall include software to automatically maintain the detector's desired sensitivity level by adjusting for the effects of environmental factors, including the accumulation of dust in each detector. The analog information may also be used for automatic detector testing and the automatic determination of detector maintenance requirements.

H. Enclosures:

1. The control panel shall be housed in a UL-listed cabinet suitable for surface or semi-flush mounting. The cabinet and front shall be corrosion protected, given a rust-resistant prime coat, and manufacturer's standard finish.
2. The back box and door shall be constructed of 0.060 steel with provisions for electrical conduit connections into the sides and top.

3. The door shall provide a key lock and shall include a glass or other transparent opening for viewing of all indicators. For convenience, the door may be site configured for either right or left hand hinged.

4. The control unit shall be modular in structure for ease of installation, maintenance, and future expansion.

I. Power Supply:

1. The Addressable Main Power Supply shall operate on 120/240 VAC, 50/60 Hz, and shall provide all necessary power for the FACP.

2. The Addressable Main Power Supply shall provide 9 amps of power to the CPU, using a switching 24 VDC regulator and shall incorporate a battery charger for 24 hours of standby power using dual-rate charging techniques for fast battery recharge.

3. The Addressable Main Power Supply shall provide a battery charger for 24 hours of standby using dual-rate charging techniques for fast battery recharge. The supply shall be capable of charging batteries ranging in capacity from 25-200 amp-hours within a 48-hour period.

4. The Addressable Main Power Supply shall provide a very low frequency sweep earth detect circuit, capable of detecting earth faults.

5. The Addressable Main Power Supply shall be power-limited per 1995 UL864 requirements.

J. Digital Voice Command

1. A Digital Voice Command System shall be available and integrated into the fire alarm system. It shall have evacuation messaging, paging, and fire fighter telephone capabilities for high-rise applications.

2. Shall have as minimum requirements:

- a. Integral 25 Watt, 25 Vrms audio amplifier.
- b. Speaker circuits that can be wired either Class A or B.
- c. Integral Digital Message Generator with a capacity of up to 60 seconds. The Digital Message Generator shall be capable of primary and secondary messages (30 seconds each). These messages shall be field programmable without the use of additional equipment.
- d. Built in alert tone generators with steady, slow whoop, high/low and chime tone field programmable.
- e. Integral Diagnostic LEDs for Power, System Trouble, Message Generator Trouble, Tone Generator Trouble, and Alarm.

4. The Voice Control Panel shall be fully supervised including microphone, amplifier output, message generator, speaker wiring, and tone generators.

5. Speaker outputs shall be fully power-limited.

K. Auxiliary Field Power Supply - Addressable

1. The auxiliary addressable power supply is a remote 24 VDC power supply used to power Notification Devices and field devices that require regulated 24VDC power. The power supply shall also include and charge backup batteries.

2. The addressable power supply for the fire alarm system shall provide up a minimum of 6.0 amps of 24-volt DC regulated power for Notification Appliance Circuit (NAC) power or 5 amps of 24 volt DC general power. The power supply shall have an additional .5 amp of 24 VDC auxiliary power for use within the same cabinet as the power supply. It shall include an integral charger designed to charge 7.0 - 25.0 amp hour batteries.

3. The addressable power supply shall provide four individually addressable Notification Appliance Circuits that may be configured as two Class "A" and two Class "B" or four Class "B" only circuits. All circuits shall be power-limited per UL 864 requirements.

4. The addressable power supply shall provide built-in synchronization for certain Notification Appliances on each circuit without the need for additional synchronization modules. The power supply's output circuits shall be individually selected for synchronization. A single addressable power supply shall be capable of supporting both synchronized and non-synchronized Notification Devices at the same time.
5. The addressable power supply shall operate on 120 or 240 VAC, 50/60 Hz.
6. The interface to the power supply from the Fire Alarm Control Panel (FACP) shall be via the Signaling Line Circuit (SLC) or other multiplexed means. Power supplies that do not use an intelligent interface are not suitable substitutes. The required wiring from the FACP to the addressable power supply shall be a single unshielded twisted pair wire.
7. The addressable power supply shall supervise for battery charging failure, AC power loss, power brownout, battery failure, NAC loss, and optional ground fault detection. In the event of a trouble condition, the addressable power supply shall report the incident and the applicable address to the FACP via the SLC.
8. The addressable power supply shall have an AC Power Loss Delay option. If this option is utilized and the addressable power supply experiences an AC power loss, reporting of the incident to the FACP will be delayed. A delay time of eight or sixteen hours shall be Dip-switch selected.
9. The addressable power supply mounts in either the FACP back box or its own dedicated surface mounted back box with cover.
10. Each of the power supply's four output circuits shall be DIP-switch selected for Notification Appliance Circuit or General Purpose 24 VDC power. Any output circuit shall be able to provide up to 2.5 amps of 24 VDC power.
11. The addressable power supply's output circuits shall be individually supervised when they are selected to be either a Notification Appliance Circuit when wired Class "A" or by the use of an end-of-line resistor. When the power supply's output circuit is selected as General 24VDC power, the circuit shall be individually supervised when an end-of-line relay is used.

12. When selected for Notification Appliance Circuits, the output circuits shall be individually DIP-switch selectable for Steady, March Time, Dual Stage or Temporal.

13. When selected as a Notification Appliance Circuit, the output circuits of the addressable power supply shall have the option to be coded by the use of a universal zone coder.

14. The addressable power supply shall interface and synchronize with other power supplies of the same type. The required wiring to interface multiple addressable power supplies shall be a single unshielded, twisted pair wire.

15. An individual or multiple interfaced addressable power supplies shall have the option to use an external charger for battery charging. Interfaced power supplies shall have the option to share backup battery power.

L. Field Charging Power Supply: The FCPS is a device designed for use as either a remote 24 volt power supply or to power Notification Appliances and provide synchronization signals to visual strobe devices.

1. The FCPS shall be available in two models offering either up to 6.0 amps (4.0 amps continuous) or 8.0 amps (6.0 amps continuous) of regulated 24-volt power. It shall include an integral charger designed to charge 7.0 amp hour batteries and to support 60-hour standby.

2. The Field Charging Power Supply shall have two input triggers. The input trigger shall be a Notification Appliance Circuit (from the fire alarm control panel) or a relay. Four outputs (two Style Y or Z and two style Y) shall be available for connection to the Notification devices.

3. The FCPS shall include an attractive surface mount back box.

4. The Field Charging Power Supply shall include the ability to delay the AC fail delay per NFPA requirements.

5. The FCPS include power limited circuitry, per 1995 UL standards.

M. System Circuit Supervision:

1. The FACP shall supervise all circuits to intelligent devices, annunciators and conventional peripherals and annunciate loss of communications with these devices. The CPU shall continuously scan above devices for proper system operation and upon loss of response from a device shall sound an audible trouble, indicate that device or devices are not responding and print the information in the history buffer and on a printer.
2. Sprinkler system valves, standpipe control valves, PIV and main gate valves shall be supervised for off-normal position.

N. Field Wiring Terminal Blocks: All wiring terminal blocks shall be the plug-in/removable type and shall be capable of terminating up to 12 AWG wire. Terminal blocks that are permanently fixed to the PC board are not acceptable.

O. System Expansion: Design the main FACP so that the system can be expanded in the future (to include the addition of twenty percent more circuits or zones) without disruption or replacement of the existing control panel. This shall include hardware capacity, software capacity and cabinet space.

P. Field Programming

1. The system shall be programmable, configurable and expandable in the field without the need for special tools, laptop computers, or other electronic interface equipment. There shall be no firmware changes required to field modify the system time, point information, equations, or annunciator programming/information.
2. It shall be possible to program through the standard FACP keyboard all system functions.
3. All field defined programs shall be stored in non-volatile memory.
4. Two levels of password protection shall be provided in addition to a key-lock cabinet. One level shall be used for status level changes such as point/zone disable or manual on/off commands (Building Manager). A second (higher-level) shall be used for actual

change of the life safety program (installer). These passwords shall be five (5) digits at a minimum. Upon entry of an invalid password for the third time within a one minute time period an encrypted number shall be displayed. This number can be used as a reference for determining a forgotten password.

5. The system programming shall be "backed" up on a CD ROM utilizing an upload/download program. This system back-up disk shall be completed and given in duplicate to the building owner and/or operator upon completion of the final inspection. The program that performs this function shall be "non-proprietary", in that, it shall be possible to forward it to the building owner/operator upon his or her request.

Q. The installer's field programming and hardware shall be functionally tested on a computer against known parameters/norms which are established by the FACP manufacturer. A software program shall test Input-to-Output correlations, device Type ID associations, point associations, time equations, etc. This test shall be performed on an IBM-compatible PC with a verification software package. A report shall be generated of the test results and two copies turned in to the engineer(s) on record.

R. It shall be the responsibility of the equipment supplier /installer to ensure that all equipment supplied will fit in locations designated on plans and in the specifications.

S. Specific System Operations

1. Smoke Detector Sensitivity Adjust: Means shall be provided for adjusting the sensitivity of any or all analog intelligent smoke detectors in the system from the system keypad or from the keyboard of the video terminal. Sensitivity range shall be within the allowed UL window.

2. Alarm Verification: Each of the Intelligent Addressable Smoke Detectors in the system may be independently selected and enabled to be an alarm verified detector. The alarm verification function shall be programmable from 5 to 50 seconds and each detector shall be able to be selected for verification during the field programming of the system or anytime after system turn-on. Alarm verification shall not require any additional hardware to be added to the control panel. The FACP shall keep a count of the number of times that each detector has entered the verification cycle. These counters may be displayed and reset by the proper operator commands.

3. System Point Operations:

a. Any addressable device in the system shall have the capability to be enabled or disabled through the system keypad or video terminal.

b. System output points shall be capable of being turned on or off from the system keypad or the video terminal.

4. Point Read: The system shall be able to display the following point status diagnostic functions without the need for peripheral equipment. Each point shall be annunciated for the parameters listed:

a. Device Status.

b. Device Type.

c. Custom Device Label.

d. Software Zone Label.

e. Device Zone Assignments.

f. Analog Detector Sensitivity.

g. All Program Parameters.

5. System Status Reports: Upon command from an operator of the system, a status report will be generated listing all system statuses:

6. System History Recording and Reporting: The fire alarm control panel shall contain a history buffer that will be capable of storing up to 4000 system events. Each of these events will be stored, with time and date stamp, until an operator requests that the contents be displayed. The contents of the history buffer may be manually reviewed, one event at a time, and the actual number of activations may also be displayed. The history buffer shall use non-volatile memory. Systems that use volatile memory for history storage are not acceptable.

7. Automatic Detector Maintenance Alert: The fire alarm control panel shall automatically interrogate each intelligent system detector and shall analyze the detector responses over a period of time. If any intelligent detector in the system responds with a reading that is below or above normal limits, then the system will enter the trouble mode,

and the particular Intelligent Detector will be annunciated on the system display. This feature shall in no way inhibit the receipt of alarm conditions in the system, nor shall it require any special hardware, special tools or computer expertise to perform.

8. The system shall include the ability (programmable) to indicate a "pre-alarm" condition. This will be used to alert maintenance personal when a detector is at 80% of its alarm threshold in a 60 second period.

2.5. SYSTEM COMPONENTS:

A. Programmable Electronic Speakers:

1. Electronic speakers shall operate on 24 VDC nominal.
2. Electronic speakers shall be field programmable without the use of special tools, at a sound level of at least 102 dBA measured at 10 feet from the device.
3. Shall be flush or surface mounted as shown on plans.
4. All speakers shall operate on 70 VRMS or with not less than 4 field selectable output taps from 0.25 to 2.0 Watts.
5. Speakers in corridors and public spaces shall produce a nominal sound output of 84 dBA at 10 feet (3m).
6. Speakers shall be suitable for voice communication and tone signals with frequency response that is flat within 3 dB between 400 HZ to 4000 HZ.
7. The back of each speaker shall be sealed to protect the speaker cone from damage and dust.

B. Strobe lights shall meet the requirements of the ADA, UL Standard 1971, be fully synchronized, and shall meet the following criteria:

1. The maximum pulse duration shall be 2/10 of one second.

2. Strobe intensity shall meet the requirements of UL 1971.
3. The flash rate shall meet the requirements of UL 1971.

C. Audible/Visual Combination Devices:

1. Shall meet the applicable requirements of Section A listed above for audibility.
2. Shall meet the requirements of Section B listed above for visibility.

D. Addressable Devices - General

1. Addressable devices shall provide an address-setting means using rotary decimal switches.
2. Addressable devices shall use simple to install and maintain decade (numbered 0 to 9) type address switches. Devices which use a binary address or special tools for setting the device address, such as a dip switch are not an allowable substitute.
3. Detectors shall be analog and addressable, and shall connect to the fire alarm control panel's Signaling Line Circuits.
4. Addressable smoke and thermal detectors shall provide dual (2) status LEDs. Both LEDs shall flash under normal conditions, indicating that the detector is operational and in regular communication with the control panel, and both LEDs shall be placed into steady illumination by the control panel, indicating that an alarm condition has been detected. If required, the flashing mode operation of the detector LEDs can be programmed off via the fire control panel program.
5. The fire alarm control panel shall permit detector sensitivity adjustment through field programming of the system. Sensitivity can be automatically adjusted by the panel on a time-of-day basis.
6. Using software in the FACP, detectors shall automatically compensate for dust accumulation and other slow environmental changes that may affect their performance.

The detectors shall be listed by UL as meeting the calibrated sensitivity test requirements of NFPA Standard 72, Chapter 7.

7. The detectors shall be ceiling-mount and shall include a separate twist-lock base which includes a tamper proof feature.

8. The following bases and auxiliary functions shall be available:

a. Sounder base rated at 85 DBA minimum.

b. Form-C Relay base rated 30VDC, 2.0A

c. Isolator base

9. The detectors shall provide a test means whereby they will simulate an alarm condition and report that condition to the control panel. Such a test may be initiated at the detector itself (by activating a magnetic switch) or initiated remotely on command from the control panel.

10. Detectors shall also store an internal identifying type code that the control panel shall use to identify the type of device (ION, PHOTO, THERMAL OR COMBINATION).

E. Addressable Pull Box (manual station)

1. Addressable pull boxes shall, on command from the control panel, send data to the panel representing the state of the manual switch and the addressable communication module status. They shall use a key operated test-reset lock, and shall be designed so that after actual emergency operation, they cannot be restored to normal use except by the use of a key.

2. All operated stations shall have a positive, visual indication of operation and utilize a key type reset.

3. Manual stations shall be constructed of Lexan with clearly visible operating instructions provided on the cover. The word FIRE shall appear on the front of the stations in raised letters, 1.75 inches (44 mm) or larger.

F. Intelligent Photoelectric Smoke Detector

1. The detectors shall use the photoelectric (light-scattering) principal to measure smoke density and shall, on command from the control panel, send data to the panel representing the analog level of smoke density.

G. Intelligent Ionization Smoke Detector

1. Not an acceptable means of detection.

H. Intelligent Multi Criteria Acclimating Detector

1. The intelligent multi criteria Acclimate detector shall be an addressable device that is designed to monitor a minimum of photoelectric and thermal technologies in a single sensing device. The design shall include the ability to adapt to its environment by utilizing a built-in microprocessor to determine it's environment and choose the appropriate sensing settings. The detector design shall allow a wide sensitivity window, no less than 1 to 4% per foot obscuration. This detector shall utilize advanced electronics that react to slow smoldering fires and thermal properties all within a single sensing device.

2. The microprocessor design shall be capable of selecting the appropriate sensitivity levels based on the environment type it is in (office, manufacturing, kitchen etc.) and then have the ability to automatically change the setting as the environment changes (as walls are moved or as the occupancy changes).

3. The intelligent multi criteria detection device shall include the ability to combine the signal of the thermal sensor with the signal of the photoelectric signal in an effort to react hastily in the event of a fire situation. It shall also include the inherent ability to distinguish between a fire condition and a false alarm condition by examining the characteristics of the thermal and smoke sensing chambers and comparing them to a database of actual fire and deceptive phenomena.

I. Intelligent Thermal Detectors

1. Thermal detectors shall be intelligent addressable devices rated at 135 degrees Fahrenheit (58 degrees Celsius) and have a rate-of-rise element rated at 15 degrees F (9.4 degrees C) per minute. It shall connect via two wires to the fire alarm control panel signaling line circuit.

J. Intelligent Duct Smoke Detector

1. The smoke detector housing shall accommodate an intelligent photoelectric detector, that provides continuous analog monitoring and alarm verification from the panel. Provide an extra Form C contact for direct fan shutdown.

2. When sufficient smoke is sensed, an alarm signal is initiated at the FACP, and appropriate action taken to change over air handling systems to help prevent the rapid distribution of toxic smoke and fire gases throughout the areas served by the duct system.

K. Hostile-Area Smoke Detector

1. The detector shall be designed to provide early warning smoke detection in environments where traditional smoke detectors are not practical.

2. The detector shall have a filter system to remove particles down to 25 microns.

3. This filter system shall remove unwanted airborne particles and water mist. This shall allow the detector to operate in environments where traditional smoke detectors would have nuisance alarms.

4. The filter system shall consist of 2 filters one of which is field replaceable.

5. The filter system shall have an intake fan to draw air and smoke through the filters into the sensing chamber.

6. The filter system shall be supervised so that if the filter is clogged or the fan fails the control panel reports trouble.

7. The filter system shall be powered from 24 VDC separate from the SLC communications.

8. The detector shall utilize a photoelectric sensing chamber.

L. Addressable Dry Contact Monitor Module

1. Addressable monitor modules shall be provided to connect one supervised IDC zone of conventional alarm initiating devices (any N.O. dry contact device) to one of the fire alarm control panel SLCs.

2. The monitor module shall mount in a 4-inch square (101.6 mm square), 2-1/8 inch (54 mm) minimum depth electrical box.

3. The IDC zone shall be suitable for Style D or Style B operation. An LED shall be provided that shall flash under normal conditions, indicating that the monitor module is operational and in regular communication with the control panel.

4. For difficult to reach areas, the monitor module shall be available in a miniature package and shall be no larger than 2-3/4 inch (70 mm) x 1-1/4 inch (31.7 mm) x 1/2 inch (12.7 mm). This version need not include Style D or an LED.

M. Two Wire Detector Monitor Module

1. Addressable monitor modules shall be provided to connect one supervised IDC zone of conventional 2-wire smoke detectors or alarm initiating devices (any N.O. dry contact device).

2. The two-wire monitor module shall mount in a 4-inch square (101.6 mm square), 2-1/8 inch (54 mm) minimum deep electrical box or with an optional surface back box.

3. The IDC zone shall be wired for Class B (Style B) operation. An LED shall be provided that shall flash under normal conditions, indicating that the monitor module is operational and in regular communication with the control panel.

N. Addressable Control Module

1. Addressable control modules shall be provided to supervise and control the operation

of one conventional NACs of compatible, 24 VDC powered polarized audio/visual notification appliances. For fan shutdown and other auxiliary control functions, the control module may be set to operate as a dry contact relay.

2. The control module shall mount in a standard 4-inch square (101.6 mm square), 2-1/8 inch (54 mm) minimum deep electrical box, or to a surface mounted back box.

3. The control module NAC shall be wired for Style Y (Class B) with up to 1 amp of inductive A/V signal, or 2 amps of resistive A/V signal operation, or as a dry contact (Form-C) relay. The relay coil shall be magnetically latched to reduce wiring connection requirements, and to insure that 100% of all auxiliary relay or NACs may be energized at the same time on the same pair of wires.

4. Audio/visual power shall be provided by a separate supervised power circuit from the main fire alarm control panel or from a supervised, UL listed remote power supply.

5. The control module shall be suitable for pilot duty applications and rated for a minimum of 0.6 amps at 30 VDC.

O. Addressable Relay Module

1. Addressable Relay Modules shall be available for HVAC control and other building functions. The relay shall be form C and rated for a minimum of 2.0 Amps resistive or 1.0 Amps inductive. The relay coil shall be magnetically latched to reduce wiring connection requirements, and to insure that 100% of all auxiliary relay or NACs may be energized at the same time on the same pair of wires.

P. Custom Point Graphic Annunciator Requirements

1. The annunciator will have an "ON-LINE" LED, local piezo sounder, local acknowledge, lamp test and reset switches and custom floor plan graphics to show where alarm conditions are present as shown with LED's.

2. The annunciator may be field configured to operate as a "Smoke Control Annunciator" when needed. When configured as "Fan Control," the annunciator may be used to manually control fan or damper operation and can be set to override automatic commands

to all fans/dampers programmed to the annunciator.

R. Water flow Indicators:

1. Waterflow Switches shall be an integral, mechanical, non-coded, non-accumulative retard type.
2. Water flow Switches shall have an alarm transmission delay time which is conveniently adjustable from 0 to 60 seconds. Initial settings shall be 30-45 seconds.
3. All water flow switches shall come from a single manufacturer and series.
4. Water flow switches shall be provided and connected under this section but installed by the fire sprinkler contractor.
5. Where possible, locate water flow switches a minimum of one (1) foot from a fitting which changes the direction of the flow and a minimum of three (3) feet from a valve.

S. Fire Sprinkler and Standpipe Valve Supervisory Switches:

1. Each fire sprinkler system water supply control valve riser, zone control valve, and standpipe system riser control valve shall be equipped with a supervisory switch. Standpipe hose valves, and test and drain valves shall not be equipped with supervisory switches.
2. PIV (post indicator valve) or main gate valves shall be equipped with a supervisory switch.
3. The switch shall be mounted so as not to interfere with the normal operation of the valve and adjusted to operate within two revolutions toward the closed position of the valve control, or when the stem has moved no more than one-fifth of the distance from its normal position.
4. The supervisory switch shall be contained in a weatherproof aluminum housing,

which shall provide a 3/4 inch (19 mm) conduit entrance and incorporate the necessary facilities for attachment to the valves.

5. The switch housing shall be finished in red baked enamel.
6. The entire installed assembly shall be tamper proof and arranged to cause a switch operation if the housing cover is removed, or if the unit is removed from its mounting.
7. Valve supervisory switches shall be provided and connected under this section and installed by the fire sprinkler contractor.

2.6. BATTERIES AND EXTERNAL CHARGER:

A. Battery:

1. Shall be 12 volt, Gel-Cell type.
2. Battery shall have sufficient capacity to power the fire alarm system for not less than twenty-four hours of standby plus 15 minutes of alarm upon a normal AC power failure.
3. The batteries are to be completely maintenance free. No liquids are required. Fluid level checks refilling, spills and leakage shall not be required.

B. External Battery Charger:

1. Shall be completely automatic, with constant potential charger maintaining the battery fully charged under all service conditions. Charger shall operate from a 120/240-volt 50/60 hertz source.
2. Shall be rated for fully charging a completely discharged battery within 48 hours while simultaneously supplying any loads connected to the battery.
3. Shall have protection to prevent discharge through the charger.
4. Shall have protection for overloads and short circuits on both AC and DC sides.

2.7. NETWORK INTERFACE

- A. Honeywell system shall have a Fire Network Adapter card, either wired or fiber optic, for direct connection of signal transmission to the UNC Honeywell EBi v610 server located in the IT Equipment Room Q1206 in Gray Hall. A Notifier system shall be provided with either an NFN-GW-EM-3 wired network interface card, or fiber optic equivalent in the case of a N16e or N16x, for direct connection of signal transmission to the two Onyxworks workstations, v4.62.102, located in Parsons Hall Building Automation office 1147 and the campus Police Dispatch office located on 1st floor of Gray Hall.

PART 3.0 – EXECUTION

3.1. INSTALLATION:

- A. Installation shall be in accordance with the NEC, NFPA 72, local and state codes, as shown on the drawings, and as recommended by the major equipment manufacturer.
- B. All conduit, junction boxes, conduit supports and hangers shall be concealed in finished areas and may be exposed in unfinished areas. Smoke detectors shall not be installed prior to the system programming and test period. If construction is ongoing during this period, measures shall be taken to protect smoke detectors from contamination and physical damage.
- C. All fire detection and alarm system devices, control panels and remote annunciators shall be flush mounted when located in finished areas and may be surface mounted when located in unfinished areas.
- D. The Honeywell factory trained technician in the event of a Honeywell system installation, or the Notifier factory trained technician in the event of a Notifier system installation, shall provide and install data, programming and graphics at the Honeywell EBi server in the event of a Honeywell system or the two Notifier Onyxworks workstations in the event of a Notifier system, including distribution of monitoring, control and security profiles as requested by owner, area diagrams, floor plans, key plans, key maps and screen titles, auto-navigations criteria, and guidance text including alarm messages as indicated by the owner.

3.2. TYPICAL OPERATION:

A. Except for resident living areas, actuation of any manual station, smoke detector, heat detector or sprinkler water flow switch shall cause the following operations to occur unless otherwise specified:

1. Activate all audible notification appliance circuits until silenced.
2. Activate all visual notification appliance circuits until the panel is reset.
3. Annunciate the active initiating devices and zones at the FACP and graphic annunciator.
4. Release all magnetic door holders on doors leading to adjacent zones on the floor from which the alarm was initiated.
5. A smoke detector in any elevator lobby shall, in addition to the above functions, return all elevators to the primary or alternate floor of egress.
6. Smoke detectors in the elevator machine room or top of hoist way shall return all elevators in to the primary or alternate floor of egress. Smoke detectors or heat detectors installed to shut down elevator power shall do so in accordance with ANSI A17.1 requirements and be coordinated with the electrical contractor.
7. Duct type smoke detectors shall produce a “supervisory” alarm signal at the FACP and shut down the ventilation system or close associated control dampers as appropriate.
8. Activation of any sprinkler system low air pressure switch or valve tamper switch shall cause a system supervisory alarm indication at the FACP.

B. Actuation of any Resident Living area (student dorm room) smoke detector shall cause the following operations to occur unless otherwise specified:

1. Activate the audible sounder base(s) in the unit where the alarm is initiated.
2. Activate the visual ADA notification appliances in the unit where the alarm is initiated.

3. Annunciate the active initiating devices and zones at the FACP and graphic annunciator.

C. HVAC/Smoke Control System Operation:

1. On/Auto/Off switches and status indicators (LEDS) shall be provided for monitoring and manual control of each fan, damper, HVAC control unit, stairwell pressurization fan, and smoke exhaust fan. To ensure compliance the units supplied shall meet the following UL categories: UUKL, PAZX, UDTZ, QVAX as well as the requirements of NFPA 90A, HVAC, and NFPA 92A & 92B, Smoke Control. The control System shall be field programmable for either 90A operation or 92A/B operation to allow for future use and system expansion.

2. The OFF LED shall be Yellow, the ON LED shall be green, the Trouble/Fault LED shall be Amber/Orange for each switch. The Trouble/Fault indicator shall indicate a trouble in the control and/or monitor points associated with that switch. In addition, each group of eight switches shall have two LEDS and one momentary switch which allow the following functions: An Amber LED to indicate an OFF-NORMAL switch position, in the ON or OFF position; A Green LED to indicate ALL AUTO switch position; A Local Acknowledge/Lamp Test momentary switch.

3. Each switch shall have the capability to monitor and control two addressable inputs and two addressable outputs. In all modes, the ON and OFF indicators shall continuously follow the device status not the switch position. Positive feedback shall be employed to verify correct operation of the device being controlled. Systems that indicate on/off/auto by physical switch position only are not acceptable.

4. All HVAC switches (i.e., limit switches, vane switches, etc.) shall be provided and installed by the HVAC contractor.

5. It shall be possible to meet the requirements mentioned above utilizing wall mounted custom graphic annunciators if the project requires such.

3.3. TEST:

Provide the service of a competent, factory-trained engineer or technician authorized by the manufacturer of the fire alarm equipment to technically supervise and participate during all of the adjustments and tests for the system.

1. Before energizing the cables and wires, check for correct connections and test for short circuits, ground faults, continuity, and insulation integrity with a “megger” type insulation tester.
2. Close each sprinkler system flow valve and verify proper supervisory alarm at the FACP.
3. Verify activation of all sprinkler water flow switches.
4. Open initiating device circuits and verify that the trouble signal actuates at the FACP.
5. Open signaling line circuits and verify that the trouble signal actuates at the FACP.
6. Open and short notification appliance circuits and verify that trouble signal actuates at the FACP.
7. Ground initiating device circuits and verify response of trouble signals at the FACP.
8. Ground signaling line circuits and verify response of trouble signals at the FACP.
9. Ground notification appliance circuits and verify response of trouble signals at the FACP.
10. Check presence and audibility of tone at all alarm notification devices.
11. Check installation, supervision, and operation of all intelligent smoke detectors during a walk test.
12. Each of the alarm conditions that the system is required to detect shall be introduced on the system. Verify the proper receipt and processing of the signals at the FACP and the ~~two~~ Honeywell EBi Workstation at Gray Hall located in the police department dispatch center and the two Notifier Onyxworks workstations in Gray Hall in the police

department dispatch center and Parsons Hall Building Automation Office 1147 and the correct activation of the associated control points.

13. When the system is equipped with optional features, the manufacturer's manual should be consulted to determine the proper testing procedures. This is intended to address such items as verifying controls performed by individually addressed or grouped devices, sensitivity monitoring, verification functionality and similar.

3.4. FINAL INSPECTION:

At the final inspection a factory trained representative of the manufacturer of the major equipment shall demonstrate that the systems function properly in every respect including alarm /trouble transmission to the UNC monitoring workstations in the presence of the AHJ, Owner's Representative, and General Contractor.

3.5. INSTRUCTION:

A. Provide a more general on site training and hands-on demonstration of the operation of all system components for all personnel at the site.

B. The contractor and/or the systems manufacturer's representatives shall provide a typewritten "Sequence of Operation."

-END OF SECTION 283100-